

**Project: Phase 6 Pile Remediation  
Construction Management  
& Diving Inspection Services**

**Date: January 2, 2019**

**RE: Addendum #4  
# of Pages: 2**

---

---

The following information is provided in response to specific questions received by BPCA in connection with the Phase 6 Pile Remediation Construction Management & Diving Inspection Services RFP. The submitted questions were either posed at the pre-proposal conference held on December 6, 2018 or received in writing by close of business on December 13, 2018.

**Questions:** (Answers to all question are shown in italics immediately after the question.):

- 1) The RFP Drawings show no wire mesh in any of the repairs. Can you confirm that the repairs consist of a form/jacket, without wire mesh in the annular space, only spacers? Permit drawings, Detail B show Epoxy coated wire mesh, and Detail A show just the form, with no wire.

**RESPONSE:** *The scope of work calls for the use of epoxy grout with no wire mesh. Wire mesh is only used for structural repairs, of which there are none in this phase.*

- 2) Please define 'sound concrete' ("remove any loose and/or deteriorated conc to sound conc").

**RESPONSE:** *Sound concrete is concrete that is not separated from the existing pile.*

- 3) General Notes on G-004 state that 'The Contractor shall provide an office trailer for the construction manager and/or Inspection team on the barges, one in the north and one in the south': Is BPCA therefore anticipating the marine contractor to be working two areas at the same time?

**RESPONSE:** *At the time of this addendum, a general contractor has not been selected. The general contractor will submit their means and methods to perform the work.*

- 4) RFP Page 9, VII. Insurance Requirements, C) Insurance Requirements for all Subcontractors "Subcontractors will also be required to obtain all other insurances listed in Section (2) unless otherwise approved in writing by BPCA prior to commencement of any Subcontractor's work."  
Q - Aside from those listed in the referenced section, please advise what other insurances are required of subcontractors as there is no Section (2) in the RFP.

**RESPONSE:** *The requirements should read "Subcontractors will also be required to obtain all other insurances listed in Section (B) unless otherwise approved in writing by BPCA prior to commencement of any Subcontractor's work."*

By signing the line below, I am acknowledging that all pages of the addendum has been received, reviewed and understood, and will be incorporated into the bid price submitted. This document must be attached to the proposal for consideration.

\_\_\_\_\_

Print Name

\_\_\_\_\_

Signature

\_\_\_\_\_

Date

Number of pages received: \_\_\_\_\_<fill in>

Distributed to: All present and all prospective Proposers